

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

No. **1194**

Dated: **17** /07/2026

It is certified that an inspection team headed by :- **Divisional Sanitary Inspector**
(Name of Officers with designation) from :- **Mr. Sanjay Gangurde (Dsi)**

Name of Department/ Office) inspected the:- **Solid Waste Management Dept.**
(New Nashik Div). Horizon International Academy, Adr- Near Raje Sambhaji
Stadium, Shravan Sector, Ashvin Nagar, Nashik-422010 on **02.06.2026** checked the
water test report submitted by the school and found that the school has potable
drinking water for students and staff of the institution and is having provision for
running water in the toilets and maintaining hygienic sanitation condition in the school
building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

The above is valid for a period of :- **For One year**



To,
Horizon International Academy,
Near Raje Sambhaji Stadium,
Shravan Sector, Ashvin Nagar, Nashik-422010

Signature with Seal:  **संचालक**
Name: Dr. Avesh Pal **नाशिक महानगरपालिका, नाशिक**
Designation: Director S.W.M Dept.
Name & Address of the Office / Department



JUNIOR SCIENTIFIC OFFICER,

DISTRICT PUBLIC HEALTH LABORATORY, NASHIK.

Civil Hospital Campus, Trimbak Road, Nashik - 422001

E-mail: dphlnasik@gmail.com

Phone:- 0253-2570613

• REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE •

Sender's Name:- **HORIZON INTERNATIONAL ACADEMY.**Address :- **Near Raje Sambhaji Stadium, Shravan Sector Ashwin Nagar, Nashik - 422 010.**Senders Letter No. & Date :- **06-05-2026** Letter No - 61/26-27 dated - 28/04/2026Date of Sample Collection :- **06-05-2026** Laboratory Reference No. :- **05 / 216 / 05**Date of Arrival at Laboratory :- **06-05-2026**Date of Commencing Examination:- **06-05-2026**

Sr. No.	Particulars of Water Samples	Results of Analysis (As per IS 10500:2012)			Remark
		Most Probable Number of bacteria Per 100 ml.			
		Coliforms	Thermotolerant coliforms	<u>E.coli</u>	
1	R O Filter Water Sample	0	--	--	<u>Potable</u>
Receipt No :- 5148031		Fee Rs. :- 340/-			Date:- 06-05-2026
Note :- Result/ Report mentioned above is/are of sample/s submitted to this laboratory only.					
Remark :- Above Water Sample no. 1 is /are bacteriologically <u>FIT</u> for drinking purposes .However it/they can be used only after proper filtration, chlorination and retesting its bacteriological quality.					

Outward No:- **2100/26**Date:- **13.5.2026**

Beyan
Junior Scientific Officer
District Public Health Laboratory,
Nashik.